

Test Verification of Conformity

In the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced specifications at the time the tests were carried out.

Applicant Name & Address:	Quick Mount PV 2700 Mitchell Drive, Bldg. 2 Walnut Creek, CA 94598		
Product Description:	Symmetrical Mount for Steep Slope Roof Applications		
Ratings & Principle Characteristics:	<u>Fire Class Resistance Rating:</u> Class A Fire Rated for Steep Slope applications when using Type 1 listed photovoltaic modules. This system was evaluated with a 5" gap (distance between the bottom of the module frame and the roof covering), per the standard this system can be installed at any gap allowed by the manufacturers installation instructions. A perimeter guard is optional.		
Models:	QuickRack Mounting System		
Brand Name:	Quick Mount		
Relevant Standards:	UL 2703 (Section 15.2 and 15.3) Standard for Safety Mounting Systems, Mounting Devices, Clamping/Retention Devices with Flat-Plate Photovoltaic Modules and Panels, First Edition dated Jan. 28, 2015 Referencing UL1703 Third Edition revision date May 2015, (Section 31.2) Standard for Safety for Flat-Plate Photovoltaic Modules and Panels.		
Verification Issuing Office:	Intertek Testing Services NA, Inc. 8431 Murphy Drive Middleton, WI 53562		
Date of Tests:	05/28/2014 – 05/29/2014		
Revised Date:	7/30/2018- Changed allowable gap from 4" to any gap allowed by the installation instructions.		
Test Report Number(s):	103512266MID-001r1_Evaluation		
This verification is part of the full test report(s) and should be read in conjunction with them. This report does not automatically imply product certification.			
Completed by:	Christopher Zimbrich	Reviewed by:	Chad Naggs
Title:	Technician I – Fire Resistance	Title:	Technical Team Lead – Fire Resistance
Signature:		Signature:	
Date:	07/30/2018	Date:	07/30/2018

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.